



Wirral Portable Appliance Testing

Client:	Site: CW WEB DESIGN	Location: OFFICES
----------------	----------------------------	--------------------------

Asset ID: 0001	Description: LAPTOP CHARGER	User: C LARSEN	Test Instrument: V30-1082
----------------	-----------------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Insulation	18/07/2005	>99.99	MOhm	Pass
Touch Leakage	18/07/2005	<0.1	mA	Pass

Overall: Pass

Asset ID: 0002	Description: EXTENSION LEAD	User: C LARSEN	Test Instrument: V30-1082
----------------	-----------------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Earth Current	18/07/2005	25	A	Information
Earth	18/07/2005	0.07	Ohm	Pass
Insulation	18/07/2005	>99.99	MOhm	Pass
Polarity	18/07/2005			Pass

Overall: Pass

Asset ID: 0003	Description: MONITOR	User: C LARSEN	Test Instrument: V30-1082
----------------	----------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Insulation	18/07/2005	>99.99	MOhm	Pass
Touch Leakage	18/07/2005	<0.1	mA	Pass

Overall: Pass

Asset ID: 0003L	Description: MONITOR LEAD	User: C LARSEN	Test Instrument: V30-1082
-----------------	---------------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Earth Current	18/07/2005	25	A	Information
Earth	18/07/2005	0.04	Ohm	Pass
Insulation	18/07/2005	>99.99	MOhm	Pass
Polarity	18/07/2005			Pass

Overall: Pass

Asset ID: 0004	Description: COMPUTER	User: C LARSEN	Test Instrument: V30-1082
----------------	-----------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Insulation	18/07/2005	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 0004L	Description: COMPUTER LEAD	User: C LARSEN	Test Instrument: V30-1082
-----------------	----------------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Earth Current	18/07/2005	25	A	Information
Earth	18/07/2005	0.04	Ohm	Pass
Insulation	18/07/2005	>99.99	MOhm	Pass
Polarity	18/07/2005			Pass

Overall: Pass

Asset ID: 0005	Description: MONITOR	User: C LARSEN	Test Instrument: V30-1082
----------------	----------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Insulation	18/07/2005	>99.99	MOhm	Pass
Touch Leakage	18/07/2005	<0.1	mA	Pass

Overall: Pass

Asset ID: 0005L	Description: MONITOR LEAD	User: C LARSEN	Test Instrument: V30-1082
-----------------	---------------------------	----------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/07/2005			Pass
Earth Current	18/07/2005	25	A	Information
Earth	18/07/2005	0.05	Ohm	Pass